

# Annexure- C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 44

Dated: 06/05/2026

It is certified that an inspection team headed by

Neha Verma (A.E.) (Name of Officers with designation)

from PHED PHED

inspected the Joy & CHAMPION PUBLIC SR. SEC. SCHOOL, KARILA, CSAGAR)

(Name & Address of the school) on 06/05/2026 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no. 44

dated 06/05/26 of (PHED Lab)

certified that the

Joy & CHAMPION PUBLIC SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains

the hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 02 years

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

*Neha Verma*  
सहायक यंत्री  
लोक स्वा. यॉ. उपखण्ड  
क्र.1 सागर (म.प्र.)

Neha Verma  
A.E.

PHED  
Sagar

To Joy & Champion Public  
Sr. Sec. School.

In front of ITI, Khudai Road Sagar (M.P.)  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

District Water testing Laboratory, (D.W.T.L.)  
Public Health Engineering Department.P.H.E.D.  
Near TahseelSagar  
Test Report

Issue No 44 D.W.T.L./PHED/SAG /2026-27

Issue Date 06/05/2026

Nature of sample :- Drinking Water Sample / Others	Not sampled by District Water testing Lab		Unique Identification No.	
Sender's name and address: JOY&CHAMPION PUBLIC SCHOOL SAGAR KARILA,IN FROM OF ITI KHURAI ROAD SAGAR	Sender's letter no.	-	Sender's letter Date	-
	DWTLRef. No	44/26	DWTL receipt date	05/05/2026
	Date of analysis started	05/05/2026	Date of analysis completed	06/05/2026
	Quantity Of sample	2 LTR.		

## Sample details

Particulars of Samples :-				
No.	Block	Panchayat	Village	Location
1	SAGAR	SAGAR	SAGAR	IN SCHOOL
2				
3				
4				
5				

## RESULTS

No.	Characteristics ,unit and test methods	BIS -10500:2012		Test Results				
		Desirable Limit	Permissible Limit	1	2	3	4	5
1	2	3	4					
1*	Chloride as Cl in mg/l, (IS 3025 Part 32)	250	1000	44				
2*	Total Alkalinity as CaCO <sub>3</sub> in mg/l, (IS 3025 Part 23)	200	600	96				
3*	Calcium as Ca <sup>++</sup> in mg/l, (IS 3025 Part 40)	75	200	34				
4*	Magnesium as Mg <sup>++</sup> in mg/l, (IS 3025 Part 46)	30	100	14.2				
5*	Total hardness as CaCO <sub>3</sub> in mg/l, (IS 3025 Part 21)	200	600	180				
6	pH (pH scale)	6.5 to 8.5	6.5 to 8.5	7.2				
7	Iron as Fe Mg/l	1.0	1.0	0.12				
8	Nitrate as NO <sub>3</sub> Mg/l	45	45	2.6				
9	Fluoride as F Mg/l	1.0	1.5	0.20				
10	TDS Mg/l	500	2000	130.2				
11	Turbidity NTU	1.0	5.0	0.6				
12	Sulphate as SO <sub>4</sub> Mg/l	200	400	8.5				
13	Manganese as MnMg/l	0.1	0.3	0.0				
14	Faecal Coliform (TTC) per 100 ml	NIL		-				
15	Total Coliform per 100 ml	NIL for treated water and water in distribution system		Nil				
16	Arsenic By Kit Mg/l	0.01	0.01	-				

1. This report should not be produced partly or full without approval of signatory authority for legal purposes.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" in column 4, above which the sources will have to be rejected.
3. The results refer only to tested samples and parameters tested
4. Samples will be stored for a period of 7 days from the date of issue of report. (For tests from S.No. 1 to 17)
5. This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.
6. The tests marked with an \* are accredited by NABL.

Remark:-

*Aarti*  
Reviewed

*Aarti*  
Authorised Signatory  
सहायक यंत्रा  
लोक स्वा. यां. उपखण्ड  
क्र.1 सागर (म.प्र.)